

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3242-1004:103 Page 1 of 1

CATEGORY: Duct Smoke Detector, Photo. (w/ or w/o Base)

LISTEE: Air Products and Controls Inc., 1749 E. Highwood, Pontiac, MI 48340
Contact: *Richard Steele (248) 332-3900 *FAX (248) 332-8807

DESIGN: Model RW-AA-P analog addressable duct smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a photoelectric duct smoke detector for use in ducts where the velocity is between 500 and 4000 ft/min. Unit employs Apollo's listed smoke detector model 55000-650 and model 45681-210 base (CSFM Listing No. 7272-1394:104).

*Rev. 05-28-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**